



Santa Margarita Groundwater Agency Workshop

City of Roseville Environmental Utilities – Aquifer Storage and Recovery (ASR) Project Overview


September 7, 2022

ASR Well Locations



Brief History and Groundwater Planning

A Brief History



Roseville's Groundwater Program

- Organizational Construct



- Objectives

- Quality
- Quantity
- Readiness
- Sustainability

- Work Elements/Actions




Roseville's Groundwater Program Goal

To operate and maintain facilities that can recharge, store, and recover water to improve the City's water supply reliability benefiting the economy, the environment, and sustainable management of water resources.



Hydrogeology, Water Quality, and Other Technical Considerations

Roseville Geology



Source: Modified from Bulletin 118-3 (DWR, 1974)

Injection and Extraction




Figure 15. Cone of Depression Resulting from Well Pumping (Heath, 1983)

Injection and Extraction (cont.)






Figure 16. Groundwater Mound During Well Injection


ASR Project - Water Quality



Native
Groundwater



Injection
Water



Blended
Water

Public Outreach & Engagement

Brochures and ASR Movie

CITY OF
ROSEVILLE
CALIFORNIA
Environmental
Utilities

CITY OF ROSEVILLE'S ASR Program

The City of Roseville's (Roseville) Aquifer Storage and Recovery (ASR) Program is an ongoing effort by the City to increase the reliability, maintain groundwater as a sustainable resource, and meet regional conjunctive use goals consistent with the Sacramento-San Joaquin River Delta Water Quality Control Plan.

Roseville's primary water source is Folsom Lake service contract with the U.S. Bureau of Reclamation and partnerships with the City of Sacramento. During the last drought, we experienced fluctuating supply when Folsom Lake was at its lowest level.


Projecting Climate Change Impacts on our Water

As part of Reclamation's WaterSMART program, regional partners are participating in the American West Water Assessment, which is a comprehensive watershed-level look at climate change impacts on the Sacramento region. Results of the assessment indicate temperature increases of 5 degrees to 6 degrees Fahrenheit, which will result in less snow and more rain. Impacts include increased flood risk in the winter months, reduced releases from Folsom Reservoir and reduced water availability during summer and fall. In addition, the need for water storage is expected to increase by 7 percent to 8 percent as a result of longer and higher intensity rain events.

Runoff from snowmelt is expected to peak earlier in the spring, resulting in more flood releases from Folsom Reservoir and reduced water availability for Folsom for use during summer and fall.




Treated drinking water is injected into aquifers with use of wells when surplus water is available.



Stored water is extracted from wells during times of need such as a drought or during peak demands.

water in an aquifer through a specially designed groundwater wells during times when water is available, and recovery (or extraction) of the water from the same well during times when it is needed. The major source of water for our ASR wells will come from excess surface water supplies such as flood flows that would have otherwise gone to waste or through the transfer of surface water from other entities.



CITY OF
ROSEVILLE
CALIFORNIA

Water Rights, Regulatory, & Permitting

Water Rights and Surface Water Availability

Production and Recharge Timing Constraints

SRI Year Type	#of years (%)	GW Production (for City)	GW Production (for Regional/Statewide)	Recharge
Wet	28 (30%)	No (<1%)	No need/market	Yes - CVP (if WFA is Wet/Average - MFP)
Above Normal	13 (14%)	No (<1%)	No need/market	Yes - CVP (if WFA is Wet/Average - MFP)
Below Normal	17 (18%)	No (<1%)	Yes (some need/market)	Yes - CVP (if WFA is Wet/Average - MFP)
Dry	21 (22%)	No (<1%)	Yes	No
Critical	15 (16%)	Yes	Yes	No

WFA Year Type	#of years (%)
Wet	51 (54%)
Average	23 (24%)
Dry	17 (18%)
Driest	3 (3%)

Regional Water Quality Control Board

STATE WATER RESOURCES CONTROL BOARD WATER QUALITY ORDER 2012-0010

GENERAL WASTE DISCHARGE REQUIREMENTS FOR AQUIFER STORAGE AND RECOVERY PROJECTS THAT INJECT DRINKING WATER INTO GROUNDWATER

The State Water Resources Control Board (State Water Board) finds that:

1. A stable supply of high quality water is critical to the continued welfare, wellbeing, and economic development of California. According to the California Department of Water Resources (DWR), the demand on groundwater will continue to increase as California's population grows from 37 million (2005 estimate) to a projected 60 million by 2050 based on current trends.
2. Groundwater is an important water source for municipal water supply, agriculture, and individual water users across California. According to the DWR 2009 Water Plan:
 - a. In 1995, an estimated 13 million Californians, nearly 43 percent of the state's population, were served by groundwater. Many small to moderate-sized towns and cities (e.g., Fresno, Davis, Lodi) rely solely on groundwater for their drinking water supplies. California public water supply systems use more than 16,000 wells to supply water to the public.
 - b. Groundwater has played a leading role in transforming California into the nation's top agricultural producer, most populous state, and the seventh largest economy in the world.
 - c. With the growing limitations on available surface water exported through the Sacramento-San Joaquin Delta and the potential impacts of climate change, reliance on groundwater through conjunctive management (i.e., coordinated and planned use and management of surface water and groundwater resources together to maximize the availability and reliability of water supplies) will become increasingly important in meeting the state's future water needs.
 - d. In some areas of the state, groundwater has been overdrafted, resulting in lowered groundwater elevations and reduced groundwater storage. A comprehensive assessment of overdraft in the state's groundwater basins has not been conducted since the 2003 update of DWR Bulletin 118-80, but it is estimated that overdraft is between 1 million and 2 million acre-feet annually.
 - e. Other basins may be subject to overdraft in the future if current water management practices are continued. Overdraft can result in increased water production costs, land subsidence, water quality impairment, and environmental degradation.
3. According to DWR Bulletin 118-80, a basin is subject to critical conditions of overdraft when present water management practices would probably result in significant adverse overdraft-related environmental, social, or economic impacts. The following eleven basins were identified as being in a critical condition of overdraft:

Pajaro Basin	Cuyama Valley Basin	Eastern San Joaquin County Basin
Kern County Basin	Chowchilla Basin	Madera Basin
Kings Basin	Kaweah Basin	Tulare Lake Basin
Tule Basin	Ventura Central Basin	

STATE WATER RESOURCES CONTROL BOARD MONITORING AND REPORTING PROGRAM – ORDER WQ 2012-0010 GENERAL WASTE DISCHARGE REQUIREMENTS FOR AQUIFER STORAGE AND RECOVERY PROJECTS THAT INJECT DRINKING WATER INTO GROUNDWATER

This Monitoring and Reporting Program (MRP) allows determination of the potential for groundwater degradation and incorporates requirements for monitoring of injected water and groundwater. This MRP is issued pursuant to Water Code section 13267. The Permittee shall not implement any changes to this MRP unless and until a revised MRP is issued by the Executive Officer.

All samples shall be representative of the volume and nature of the monitored medium. The time, date, and location of each grab sample shall be recorded on the sample chain of custody form. Injection flow monitoring shall be conducted continuously using a flow meter and shall be reported in gallons per day and cumulative totals.

Field test instruments (such as those used to monitor pH) may be used provided that:

1. The operator is trained in the proper use of the instrument;
2. The instruments are field calibrated prior to each use;
3. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are submitted as described in the "Reporting" section of this MRP.

INJECTION WELL MONITORING

Injection wells shall be monitored when water is being injected into the aquifer. Monitoring of the injection wells shall include, at a minimum, the following

Constituent/Parameter	Units	Type of Sample Recorded	Sampling Frequency	Reporting Frequency
Well Operational Status ¹	N/A	Meter	Daily	Quarterly
Daily Average Injection Rate	gpd ²	Meter	Continuous	Quarterly
Injected Water, cumulative total for year to date	ac-ft/yr	Meter	Continuous	Quarterly
Extracted Water, cumulative total for year to date	ac-ft/yr	Meter	Continuous	Quarterly


- ¹ Well Operational Status shall be reported for each well associated with the ASR project. Injection activity shall be recorded on a daily basis.
- ² Alternative units may be used to report the data.

INJECTED WATER MONITORING


Injected water is limited to potable water that the Permittee produces through its CDPH permitted domestic water supply permit. Section 116470 of the California Health and Safety Code requires:

1. An Annual Water Quality Report (AWQR). The AWQR characterizes the injected water.
2. Public water systems that serve more than 10,000 service connections and that detect one or more contaminants in drinking water that exceed the applicable public health goal, are required to prepare a report that addresses the contaminant issue.


Groundwater Contours (during ASR)




Water Quality (Iron)



Water Quality (Arsenic)



Flowrate and Volume



Planning & Design

ASR Well – Design Aesthetics

Diamond Creek (Well No. 6)



Blue Oaks Blvd (Well No. 12)



Well & Pump Station Design





Figure 4. General Well Design

Well & Pump Station Design (cont.)

Baski Flow Control Valve



Stainless steel casing, screen, and sounding port +/- \$120,000

Stainless steel casing and screen are used in ASR wells to increase well lifespan and performance. Stainless steel helps combat corrosion, reduce from bacterial growth, and is a longer lasting material than HSLA or other lower grade metals. Oxygenated and potentially corrosive water used for injection can lead to corrosion and weakening of mild steel, and iron-rich water can lead to precipitates and fee bacterial growth, reducing well performance. Using stainless steel reduces these risks along with maintenance and rehabilitation costs associated. Stainless steel is widely being used for traditional supply wells as well.




Flow Control Device - +approx. \$90,000:

Flow control devices give operators greater control on injection rates and help to eliminate potential air entrainment in the aquifer which can reduce well performance. Flow control devices operate by adjusting the opening in which injected water can pass through and therefore regulating flow. They are controlled through either compressed gas or hydraulic fluid. Hydraulic flow control devices, such as the 3R device pictured, allow for fining tuning of injection than compressed gas systems and can be used to surge the well through cycling injection/extraction modes. Well surging helps to maintain well capacity.



SiLi Beads - +\$10,000

SiLi beads are perfectly spherical glass beads that are used for filter pack in place of traditional silica sand. Their shape and construction can provide greater well performance through increased void space and improved effectiveness in maintenance/rehabilitation. The glass construction of the beads also inhibits bacterial growth that can hinder well performance. SiLi beads are not necessary for an ASR well and there are programs that argue whether there is enough increase in well performance, if any, to justify the increase in costs.




Operations

SCADA (cont.)

Well 6 - Diamond Creek

DMZSCADA
7:31:39 AM
2/26/2020


Plant Overview | Water Quality Overview | Process | Chemical System | Reclaim Basins | Centrifuge | DPPS | Distribution Overview | Wells | SWPS | Trends | Diagnostics




Ack	Priority	Date In	Time In	Tagname	Description	Value	Status
1	✓ HIHI	2/24/2020	14:24:31.109	WT55_LSLX_00318	FILTER 3R AT MEDIA LEVEL	AT MEDIA LEVEL	CFN
2	✓ HIHI	2/19/2020	17:18:57.186	SW14_YAFX_05100	W. COLONIAL PUMP 1 FAIL	ALARM	CFN
3	✓ HIHI	2/19/2020	19:59:25.976	WT04_YAFX_00011	WEST END PUMP WATER CHLORINE ANALYZER	ALARM	CFN
4	✓ CRITICAL	2/11/2020	11:57:36.996	IGS_WD02_PRS_2_ERROR	CANEVARI PRS IGS ERROR	ALARM	CFN

ASR Well Operational Modes

Injection



Extraction



ASR Well Performance and Backwashing

Well 12 Consecutive Injection Periods With Theis Curve





Figure A-6: City of Roseville Well 8 Specific Capacity Trend



Questions and Comments



Trevor Joseph, P.G., C.Hg.
tjoseph@roseville.ca.us
(916) 517-2578